

Planned Outage

Name of the Licensee: *INDIA POWER CORPORATION LIMITED*
 From Date : *29-11-2018*

To Date : *30-11-2018*

Sl. No.	Feeder / Transformer Name & Number	Time of outage	Time of Restoration	Duration in minutes	Affected area connected to respective feeder /substation	Input load in kW at the time of outage	Input load in kW at the time of restoration	Interruption Reference Number	No. of Objection received from Consumers	Reply given to the objections	Estimated Energy loss in MU
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
1	Sitaldasji	29-11-2018 10:00	29-11-2018 11:35	95	All consumers under SitaldasjiFeeder	2429	2429	PSTDSJ20181129038			0.0038
2	Nandi Line	29-11-2018 10:05	29-11-2018 11:00	55	All consumers under Nandi LineFeeder	49	49	PNAND20181129027			0.0000
3	Ranjit Auto	29-11-2018 10:17	29-11-2018 12:17	120	All consumers under Ranjit AutoFeeder	56	19	PRNJTAUT20181129008			0.0001
4	East Ring North Ckt	29-11-2018 11:40	29-11-2018 12:30	50	All consumers under East Ring North CktFeeder	65	65	PERN20181129017			0.0001
5	East Ring-4	29-11-2018 12:20	29-11-2018 12:40	20	All consumers under East Ring-4Feeder	485	261	PER420181129015			0.0001
6	Industrial 1	29-11-2018 16:10	29-11-2018 16:50	40	All consumers under Industrial 1Feeder	259	259	PINDUST120181129019			0.0002
7	Industrial 1	30-11-2018 10:35	30-11-2018 11:05	30	All consumers under Industrial 1Feeder	259	259	PINDUST120181130020			0.0001
8	Kanyapur Industiral	30-11-2018 10:40	30-11-2018 13:12	152	All consumers under Kanyapur IndustiralFeeder	1027	784	PKANYIND20181130023			0.0023
9	Industrial 1	30-11-2018 13:05	30-11-2018 13:20	15	All consumers under Industrial 1Feeder	259	259	PINDUST120181130021			0.0001

Un-Planned Outage

Name of the Licensee: *INDIA POWER CORPORATION LIMITED*
 From Date : *29-11-2018*

To Date : *30-11-2018*

Sl. No.	Feeder / Transformer Name & Number	Time of outage	Time of Restoration	Duration in minutes	Affected area connected to respective feeder /substation	Input load in kW at the time of outage	Input load in kW at the time of restoration	Interruption Reference Number	No. of Objection received from Consumers	Reply given to the objections	Estimated Energy loss in MU
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
1	Kenda 1	30-11-2018 01:15	30-11-2018 03:32	137	All consumers under Kenda 1Feeder	648	648	UKEND120181130001			0.0015