

Planned Outage

Name of the Licensee: *INDIA POWER CORPORATION LIMITED*
 From Date : *01-05-2020*

To Date : *07-05-2020*

Sl. No.	Feeder / Transformer Name & Number	Time of outage	Time of Restoration	Duration in minutes	Affected area connected to respective feeder /substation	Input load in kW at the time of outage	Input load in kW at the time of restoration	Interruption Reference Number	No. of Objection received from Consumers	Reply given to the objections	Estimated Energy loss in MU
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
1	Anjana Rice mill (11 KV)	01-05-2020 13:30	01-05-2020 14:20	50	All consumers under Anjana Rice mill (11 KV) Feeder	747	280	PLANJ202005010030			0.0004
2	Kunustoria tie	02-05-2020 11:01	02-05-2020 11:29	28	All consumers under Kunustoria tie Feeder	12	12	PLKUN202005020018			0.0000
3	West ring North Ckt 1	02-05-2020 11:18	02-05-2020 12:28	70	All consumers under West ring North Ckt 1 Feeder	24	24	PLWES202005020029			0.0000
4	Tr. No.3 at LRS	04-05-2020 16:50	04-05-2020 17:30	40	All consumers under Tr. No.3 at LRS Feeder	0	0	PLTRN202005040009			0.0000
5	Tr. No. 1 at LRS	05-05-2020 10:45	05-05-2020 11:57	72	All consumers under Tr. No. 1 at LRS Feeder	0	0	PLTRN202005050006			0.0000
6	Haripur 2	06-05-2020 11:10	06-05-2020 13:00	110	All consumers under Haripur 2 Feeder	2	2	PLHAR202005060017			0.0000
7	KLS	06-05-2020 13:40	06-05-2020 14:55	75	All consumers under KLS Feeder	478	478	PLKLS202005060059			0.0006
8	JKNagar-Ikrah R/M	07-05-2020 10:30	07-05-2020 11:00	30	All consumers under JKNagar-Ikrah R/M Feeder	1258	1258	PLJKN202005070021			0.0006
9	Haripur 2	07-05-2020 11:00	07-05-2020 12:55	115	All consumers under Haripur 2 Feeder	18	18	PLHAR202005070018			0.0000
10	Shyam Sel 33 KV Feeder	07-05-2020 18:00	07-05-2020 18:37	37	All consumers under Shyam Sel 33 KV Feeder Feeder	0	0	PLSHY202005070009			0.0000

Un-Planned Outage

Name of the Licensee: *INDIA POWER CORPORATION LIMITED*
 From Date : *01-05-2020*

To Date : *07-05-2020*

Sl. No.	Feeder / Transformer Name & Number	Time of outage	Time of Restoration	Duration in minutes	Affected area connected to respective feeder /substation	Input load in kW at the time of outage	Input load in kW at the time of restoration	Interruption Reference Number	No. of Objection received from Consumers	Reply given to the objections	Estimated Energy loss in MU
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
1	Kanyapur Industrial (11 KV)	01-05-2020 14:40	01-05-2020 17:07	147	All consumers under Kanyapur Industrial (11 KV) Feeder	467	180	UPKAN202005010041			0.0008
2	Sripur	01-05-2020 14:56	01-05-2020 17:50	174	All consumers under Sripur Feeder	89	89	UPSRI202005010041			0.0003
3	Kajora Siduli R/M 2	01-05-2020 17:30	01-05-2020 18:50	80	All consumers under Kajora Siduli R/M 2 Feeder	4	4	UPKAJ202005010025			0.0000
4	Panchgachia (11 KV)	02-05-2020 09:05	02-05-2020 12:12	187	All consumers under Panchgachia (11 KV) Feeder	299	95	UPPAN202005020046			0.0006
5	Kanyapur Industrial (11 KV)	02-05-2020 13:01	02-05-2020 16:56	235	All consumers under Kanyapur Industrial (11 KV) Feeder	560	210	UPKAN202005020042			0.0015
6	Indian Oxygen No. 1 (11 KV)	06-05-2020 03:02	06-05-2020 05:03	121	All consumers under Indian Oxygen No. 1 (11 KV) Feeder	187	75	UPIND202005060016			0.0003
7	Aakriti Commerce (11 KV)	06-05-2020 05:50	06-05-2020 07:55	125	All consumers under Aakriti Commerce (11 KV) Feeder	93	37	UPAAK202005060020			0.0001
8	Tr. No.2 at Mangalpur S/Stn	07-05-2020 18:00	07-05-2020 18:37	37	All consumers under Tr. No.2 at Mangalpur S/Stn Feeder	0	0	UPTRN202005070007			0.0000
9	Kajora Siduli R/M 2	07-05-2020 18:15	07-05-2020 18:45	30	All consumers under Kajora Siduli R/M 2 Feeder	4	4	UPKAJ202005070026			0.0000