

Planned Outage

Name of the Licensee: *INDIA POWER CORPORATION LIMITED*
From Date : *08-11-2018*

To Date : *14-11-2018*

Sl. No.	Feeder / Transformer Name & Number	Time of outage	Time of Restoration	Duration in minutes	Affected area connected to respective feeder /substation	Input load in kW at the time of outage	Input load in kW at the time of restoration	Interruption Reference Number	No. of Objection received from Consumers	Reply given to the objections	Estimated Energy loss in MU
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
1	Jemari Khas	08-11-2018 10:28	08-11-2018 12:13	105	All consumers under Jemari KhasFeeder	729	729	PJKHAS20181108033			0.0013
2	Searsole Pumping	08-11-2018 10:55	08-11-2018 11:15	20	All consumers under Searsole PumpingFeeder	486	486	PSPUMP20181108032			0.0002
3	Shyam Sel 33 KV Feeder	08-11-2018 12:14	08-11-2018 12:33	19	All consumers under Shyam Sel 33 KV FeederFeeder	6601	2201	PSHYMS3320181108003			0.0014
4	Kenda 1	08-11-2018 15:25	08-11-2018 15:49	24	All consumers under Kenda 1Feeder	729	729	PKEND120181108010			0.0003
5	Asansol Section	09-11-2018 10:30	09-11-2018 10:58	28	All consumers under Asansol SectionFeeder	1134	1134	PANSEC20181109055			0.0005
6	Coal Board 1	09-11-2018 10:45	09-11-2018 11:00	15	All consumers under Coal Board 1Feeder	18	18	PCB120181109032			0.0000
7	Coal Board 1	09-11-2018 11:15	09-11-2018 11:32	17	All consumers under Coal Board 1Feeder	18	18	PCB120181109033			0.0000
8	Kenda 1	09-11-2018 11:30	09-11-2018 11:55	25	All consumers under Kenda 1Feeder	729	729	PKEND120181109011			0.0003
9	Industrial 3	09-11-2018 11:44	09-11-2018 12:00	16	All consumers under Industrial 3Feeder	907	907	PINDUST320181109008			0.0002
10	Shivam Dhatu (33 kV)	09-11-2018 13:00	09-11-2018 13:25	25	All consumers under Shivam Dhatu (33 kV)Feeder	324	324	PSHIVAM3320181109001			0.0001
11	Coal Board 1	10-11-2018 11:00	10-11-2018 11:32	32	All consumers under Coal Board 1Feeder	1131	848	PCB120181110034			0.0005
12	Coal Board 1	10-11-2018 16:10	10-11-2018 16:30	20	All consumers under Coal Board 1Feeder	1131	848	PCB120181110035			0.0003
13	Kunustoria Tie	11-11-2018 10:55	11-11-2018 11:15	20	All consumers under Kunustoria TieFeeder	40	40	PKNSTT20181111015			0.0000
14	Topsi Rail	11-11-2018 10:55	11-11-2018 11:15	20	All consumers under Topsi RailFeeder	486	486	PTOPSIR20181111024			0.0002
15	B Mill No. 1	12-11-2018 09:40	12-11-2018 10:05	25	All consumers under B Mill No. 1Feeder	1131	377	PBPM120181112026			0.0003
16	B Mill No. 1	12-11-2018 12:15	12-11-2018 12:30	15	All consumers under B Mill No. 1Feeder	1131	377	PBPM120181112027			0.0002
17	Raniganj Square Feeder	12-11-2018 12:50	12-11-2018 14:10	80	All consumers under Raniganj Square FeederFeeder	565	188	PRNGSQR20181112011			0.0005
18	Bansra	12-11-2018 13:50	12-11-2018 14:10	20	All consumers under BansraFeeder	194	194	PBANS20181112034			0.0001
19	B Mill No. 1	12-11-2018 13:52	12-11-2018 14:10	18	All consumers under B Mill No. 1Feeder	1131	377	PBPM120181112028			0.0002
20	Bansra	12-11-2018 15:50	12-11-2018 16:05	15	All consumers under BansraFeeder	227	227	PBANS20181112035			0.0001
21	Bansra	12-11-2018 16:15	12-11-2018 16:40	25	All consumers under BansraFeeder	227	227	PBANS20181112036			0.0001
22	North Brook	14-11-2018 09:05	14-11-2018 09:47	42	All consumers under North BrookFeeder	1457	1457	PNRTHB20181114034			0.0010
23	Jemari Khas	14-11-2018 10:35	14-11-2018 12:15	100	All consumers under Jemari KhasFeeder	729	729	PJKHAS20181114034			0.0012

Un-Planned Outage

Name of the Licensee: *INDIA POWER CORPORATION LIMITED*
From Date : *08-11-2018*

To Date : *14-11-2018*

Sl. No.	Feeder / Transformer Name & Number	Time of outage	Time of Restoration	Duration in minutes	Affected area connected to respective feeder /substation	Input load in kW at the time of outage	Input load in kW at the time of restoration	Interruption Reference Number	No. of Objection received from Consumers	Reply given to the objections	Estimated Energy loss in MU
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
1	Sitaldasji	10-11-2018 03:25	10-11-2018 05:30	125	All consumers under SitaldasjiFeeder	2105	2105	USTDSJ20181110006			0.0044