

**Planned Outage**

Name of the Licensee: *INDIA POWER CORPORATION LIMITED*  
 From Date : *15-02-2019*

To Date : *21-02-2019*

Sl. No.	Feeder / Transformer Name & Number	Time of outage	Time of Restoration	Duration in minutes	Affected area connected to respective feeder /substation	Input load in kW at the time of outage	Input load in kW at the time of restoration	Interruption Reference Number	No. of Objection received from Consumers	Reply given to the objections	Estimated Energy loss in MU
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
1	Industrial	15-02-2019 12:10	15-02-2019 12:25	15	All consumers under IndustrialFeeder	660	220	PINDUST20190215001			0.0001
2	Nandi Line	19-02-2019 09:00	19-02-2019 09:20	20	All consumers under Nandi LineFeeder	89	89	PNAND20190219004			0.0000
3	India Refactory	21-02-2019 09:54	21-02-2019 12:50	176	All consumers under India RefactoryFeeder	1046	373	PINDREFR20190221002			0.0021
4	Kulti	21-02-2019 09:54	21-02-2019 12:50	176	All consumers under KultiFeeder	37	19	PKULTI20190221001			0.0001
5	Churulia	21-02-2019 10:16	21-02-2019 10:41	25	All consumers under ChuruliaFeeder	187	149	PCHURL20190221004			0.0001
6	Damra	21-02-2019 10:17	21-02-2019 12:10	113	All consumers under DamraFeeder	972	1296	PDAM20190221004			0.0021
7	Asansol Section	21-02-2019 12:19	21-02-2019 13:25	66	All consumers under Asansol SectionFeeder	1296	1334	PASNSEC20190221004			0.0014
8	Coal Board 1	21-02-2019 16:55	21-02-2019 18:10	75	All consumers under Coal Board 1Feeder	18	18	PCB120190221002			0.0000
9	Coal Board 1	21-02-2019 22:15	21-02-2019 22:35	20	All consumers under Coal Board 1Feeder	18	18	PCB120190221003			0.0000

**Un-Planned Outage**

Name of the Licensee: *INDIA POWER CORPORATION LIMITED*  
 From Date : *15-02-2019*

To Date : *21-02-2019*

Sl. No.	Feeder / Transformer Name & Number	Time of outage	Time of Restoration	Duration in minutes	Affected area connected to respective feeder /substation	Input load in kW at the time of outage	Input load in kW at the time of restoration	Interruption Reference Number	No. of Objection received from Consumers	Reply given to the objections	Estimated Energy loss in MU
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
1	Coal Board 1	21-02-2019 11:25	21-02-2019 13:17	112	All consumers under Coal Board 1Feeder	1131	848	UCB120190221001			0.0018