

**Planned Outage**

Name of the Licensee: *INDIA POWER CORPORATION LIMITED*  
 From Date : *22-06-2019*

To Date : *28-06-2019*

Sl. No.	Feeder / Transformer Name & Number	Time of outage	Time of Restoration	Duration in minutes	Affected area connected to respective feeder /substation	Input load in kW at the time of outage	Input load in kW at the time of restoration	Interruption Reference Number	No. of Objection received from Consumers	Reply given to the objections	Estimated Energy loss in MU
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
1	Coal Board 1	23-06-2019 18:18	23-06-2019 18:37	19	All consumers under Coal Board 1 Feeder	18	6	PLCOA201906230012			0.0000
2	Searsol Point	24-06-2019 18:50	24-06-2019 19:09	19	All consumers under Searsol Point Feeder	96	96	PLSEA201906240001			0.0000
3	Industrial 3	25-06-2019 10:05	25-06-2019 11:55	110	All consumers under Industrial 3 Feeder	1236	1236	PLIND201906250006			0.0023
4	Haripur 2	26-06-2019 10:25	26-06-2019 11:25	60	All consumers under Haripur 2 Feeder	9	3	PLHAR201906260008			0.0000
5	East Chora	26-06-2019 10:50	26-06-2019 12:00	70	All consumers under East Chora Feeder	9	3	PLEAS201906260006			0.0000
6	Panchgachia (11 KV)	26-06-2019 12:37	26-06-2019 13:02	25	All consumers under Panchgachia (11 KV) Feeder	934	504	PLPAN201906260014			0.0003
7	Seebpore-Ikrah R/M	26-06-2019 20:25	26-06-2019 20:45	20	All consumers under Seebpore-Ikrah R/M Feeder	4016	4016	PLSEE201906260003			0.0013
8	Asansol Section	27-06-2019 08:05	27-06-2019 08:26	21	All consumers under Asansol Section Feeder	1134	1134	PLASA201906270016			0.0004
9	B Mill No. 1	27-06-2019 09:53	27-06-2019 10:08	15	All consumers under B Mill No. 1 Feeder	1886	472	PLBMI201906270011			0.0003
10	B Mill No. 2	27-06-2019 09:53	27-06-2019 10:55	62	All consumers under B Mill No. 2 Feeder	18	6	PLBMI201906270005			0.0000
11	Ranjit Auto (11 KV)	27-06-2019 10:18	27-06-2019 12:18	120	All consumers under Ranjit Auto (11 KV) Feeder	560	187	PLRAN201906270011			0.0007
12	KLS	27-06-2019 12:03	27-06-2019 12:18	15	All consumers under KLS Feeder	729	729	PLKLS201906270023			0.0002
13	Churulia (11 KV)	27-06-2019 17:35	27-06-2019 18:29	54	All consumers under Churulia (11 KV) Feeder	187	97	PLCHU201906270007			0.0001
14	Cable 3 (11 KV)	27-06-2019 18:45	27-06-2019 20:08	83	All consumers under Cable 3 (11 KV) Feeder	1587	1120	PLCAB201906270003			0.0019
15	Churulia (11 KV)	28-06-2019 10:14	28-06-2019 10:36	22	All consumers under Churulia (11 KV) Feeder	187	112	PLCHU201906280008			0.0001
16	Incoming Oxygen or S-R Tie feeder (11 KV)	28-06-2019 10:18	28-06-2019 10:36	18	All consumers under Incoming Oxygen or S-R Tie feeder (11 KV) Feeder	1307	709	PLINC201906280007			0.0003
17	Industrial Feeder	28-06-2019 14:30	28-06-2019 14:45	15	All consumers under Industrial Feeder Feeder	943	314	PLIND201906280002			0.0002
18	Jaisalasar	28-06-2019 14:30	28-06-2019 14:45	15	All consumers under Jaisalasar Feeder	0	0	PLJAI201906280001			0.0000
19	Kajora Siduli R/M 2	28-06-2019 18:15	28-06-2019 18:40	25	All consumers under Kajora Siduli R/M 2 Feeder	0	0	PLKAJ201906280012			0.0000

**Un-Planned Outage**

Name of the Licensee: *INDIA POWER CORPORATION LIMITED*  
 From Date : *22-06-2019*

To Date : *28-06-2019*

Sl. No.	Feeder / Transformer Name & Number	Time of outage	Time of Restoration	Duration in minutes	Affected area connected to respective feeder /substation	Input load in kW at the time of outage	Input load in kW at the time of restoration	Interruption Reference Number	No. of Objection received from Consumers	Reply given to the objections	Estimated Energy loss in MU
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
1	East Ring - 4 (11 KV)	22-06-2019 04:20	22-06-2019 11:35	435	All consumers under East Ring - 4 (11 KV) Feeder	35	20	UPEAS201906220004			0.0002
2	Sen Releigh main (11 KV)	22-06-2019 04:50	22-06-2019 05:15	25	All consumers under Sen Releigh main (11 KV) Feeder	280	187	UPSEN201906220002			0.0001
3	Aakriti Commerce (11 KV)	22-06-2019 14:02	22-06-2019 17:18	196	All consumers under Aakriti Commerce (11 KV) Feeder	1307	747	UPAAK201906220005			0.0034
4	Kanyapur Industrial (11 KV)	25-06-2019 10:39	25-06-2019 13:21	162	All consumers under Kanyapur Industrial (11 KV) Feeder	934	560	UPKAN201906250011			0.0020
5	Asansol Section	26-06-2019 00:00	26-06-2019 02:35	155	All consumers under Asansol Section Feeder	1134	1134	UPASA201906260014			0.0029
6	Sen Releigh main (11 KV)	26-06-2019 11:22	26-06-2019 13:03	101	All consumers under Sen Releigh main (11 KV) Feeder	280	131	UPSEN201906260003			0.0003
7	Anand Flour Mill (11 KV)	26-06-2019 17:44	26-06-2019 18:03	19	All consumers under Anand Flour Mill (11 KV) Feeder	2614	1494	UPANA201906260001			0.0007
8	B G Tie 1 (11 KV)	26-06-2019 17:44	26-06-2019 18:03	19	All consumers under B G Tie 1 (11 KV) Feeder	1214	747	UPBGT201906260002			0.0003

Sl. No.	Feeder / Transformer Name & Number	Time of outage	Time of Restoration	Duration in minutes	Affected area connected to respective feeder /substation	Input load in kW at the time of outage	Input load in kW at the time of restoration	Interruption Reference Number	No. of Objection received from Consumers	Reply given to the objections	Estimated Energy loss in MU
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
9	Cable 3 (11 KV)	26-06-2019 17:44	26-06-2019 18:03	19	All consumers under Cable 3 (11 KV) Feeder	1587	934	UPCAB201906260001			0.0004
10	Carolina (11 KV)	26-06-2019 17:44	26-06-2019 18:03	19	All consumers under Carolina (11 KV) Feeder	560	392	UPCAR201906260003			0.0002
11	Indian Oxygen No. 1 (11 KV)	26-06-2019 17:44	26-06-2019 18:05	21	All consumers under Indian Oxygen No. 1 (11 KV) Feeder	971	504	UPIND201906260005			0.0003
12	Ranjit Auto (11 KV)	26-06-2019 17:44	26-06-2019 18:05	21	All consumers under Ranjit Auto (11 KV) Feeder	859	485	UPRAN201906260010			0.0002
13	Cable 3 (11 KV)	26-06-2019 18:10	26-06-2019 18:32	22	All consumers under Cable 3 (11 KV) Feeder	1587	934	UPCAB201906260002			0.0005
14	Asansol Section	26-06-2019 18:50	26-06-2019 20:35	105	All consumers under Asansol Section Feeder	1134	1134	UPASA201906260015			0.0020
15	Incoming Oxygen or S-R Tie feeder (11 KV)	27-06-2019 03:20	27-06-2019 06:25	185	All consumers under Incoming Oxygen or S-R Tie feeder (11 KV) Feeder	560	187	UPINC201906270006			0.0012
16	Srijan Cement	27-06-2019 15:20	27-06-2019 16:55	95	All consumers under Srijan Cement Feeder	92	92	UPSRI201906270004			0.0001
17	Sitaldas ji	27-06-2019 19:44	27-06-2019 20:50	66	All consumers under Sitaldas ji Feeder	789	789	UPSIT201906270010			0.0009
18	Cable 3 (11 KV)	28-06-2019 15:14	28-06-2019 16:49	95	All consumers under Cable 3 (11 KV) Feeder	1587	787	UPCAB201906280004			0.0019
19	Indian Oxygen No. 1 (11 KV)	28-06-2019 15:18	28-06-2019 15:39	21	All consumers under Indian Oxygen No. 1 (11 KV) Feeder	971	560	UPIND201906280006			0.0003