

Planned Outage

Name of the Licensee: INDIA POWER CORPORATION LIMITED
From Date : 01-03-2021

To Date : 07-03-2021

Sl. No.	Feeder / Transformer Name & Number	Time of outage	Time of Restoration	Duration in minutes	Affected area connected to respective feeder /substation	Input load in kW at the time of outage	Input load in kW at the time of restoration	Interruption Reference Number	No. of Objection received from Consumers	Reply given to the objections	Estimated Energy loss in MU
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
1	Devyani (33 KV)	01-03-2021 11:00	01-03-2021 11:50	50	All consumers under Devyani (33 KV) Feeder	1000	40	PLDEV202103010010			0.0004
2	Asansol Section	01-03-2021 11:10	01-03-2021 12:44	94	All consumers under Asansol Section Feeder	1325	1325	PLASA202103010027			0.0021
3	Siduli Section	01-03-2021 12:50	01-03-2021 13:05	15	All consumers under Siduli Section Feeder	18	9	PLSID202103010005			0.0000
4	Srijan Cement	01-03-2021 13:20	01-03-2021 15:18	118	All consumers under Srijan Cement Feeder	1023	1023	PLSRI202103010035			0.0020
5	Siduli Section	01-03-2021 13:22	01-03-2021 13:40	18	All consumers under Siduli Section Feeder	18	9	PLSID202103010006			0.0000
6	East Ring -1 (11 KV)	02-03-2021 10:00	02-03-2021 13:33	213	All consumers under East Ring -1 (11 KV) Feeder	200	93	PLEAS202103020006			0.0005
7	Sen Releigh main (11 KV)	02-03-2021 10:00	02-03-2021 13:33	213	All consumers under Sen Releigh main (11 KV) Feeder	187	93	PLSEN202103020003			0.0005
8	Siduli Section	02-03-2021 11:55	02-03-2021 13:50	115	All consumers under Siduli Section Feeder	18	9	PLSID202103020007			0.0000
9	Carolina (11 KV)	02-03-2021 16:35	02-03-2021 17:45	70	All consumers under Carolina (11 KV) Feeder	1120	280	PLCAR202103020010			0.0008
10	Kajora Siduli R/M 2	03-03-2021 10:45	03-03-2021 12:35	110	All consumers under Kajora Siduli R/M 2 Feeder	36	9	PLKAJ202103030034			0.0000
11	Asansol Section	03-03-2021 11:10	03-03-2021 11:30	20	All consumers under Asansol Section Feeder	1356	1356	PLASA202103030028			0.0005
12	Indian Oxygen No. 1 (11 KV)	04-03-2021 10:35	04-03-2021 11:50	75	All consumers under Indian Oxygen No. 1 (11 KV) Feeder	1120	467	PLIND202103040015			0.0010
13	Kanyapur Industrial (11 KV)	04-03-2021 10:35	04-03-2021 12:59	144	All consumers under Kanyapur Industrial (11 KV) Feeder	1307	560	PLKAN202103040030			0.0022
14	East Ring -1 (11 KV)	04-03-2021 10:55	04-03-2021 11:50	55	All consumers under East Ring -1 (11 KV) Feeder	560	224	PLEAS202103040007			0.0004
15	Panchgachia (11 KV)	04-03-2021 12:09	04-03-2021 12:34	25	All consumers under Panchgachia (11 KV) Feeder	1214	392	PLPAN202103040034			0.0003
16	Indian Oxygen No. 1 (11 KV)	04-03-2021 16:05	04-03-2021 16:50	45	All consumers under Indian Oxygen No. 1 (11 KV) Feeder	1120	467	PLIND202103040016			0.0006
17	Aakriti Commerce (11 KV)	05-03-2021 16:28	05-03-2021 17:03	35	All consumers under Aakriti Commerce (11 KV) Feeder	1120	392	PLAAK202103050019			0.0004
18	Anjana Rice mill (11 KV)	05-03-2021 16:28	05-03-2021 17:02	34	All consumers under Anjana Rice mill (11 KV) Feeder	1307	392	PLANJ202103050039			0.0005
19	B Mill No. 2	06-03-2021 10:05	06-03-2021 12:00	115	All consumers under B Mill No. 2 Feeder	94	31	PLBMI202103060019			0.0001
20	Srijan Cement	06-03-2021 10:18	06-03-2021 11:21	63	All consumers under Srijan Cement Feeder	963	963	PLSRI202103060036			0.0010
21	Ranjit Auto (11 KV)	06-03-2021 11:00	06-03-2021 11:33	33	All consumers under Ranjit Auto (11 KV) Feeder	747	187	PLRAN202103060025			0.0003
22	Aakriti Commerce (11 KV)	06-03-2021 14:52	06-03-2021 15:18	26	All consumers under Aakriti Commerce (11 KV) Feeder	1307	373	PLAAK202103060020			0.0004
23	Anjana Rice mill (11 KV)	06-03-2021 14:52	06-03-2021 15:18	26	All consumers under Anjana Rice mill (11 KV) Feeder	1494	373	PLANJ202103060040			0.0004
24	Srijan Cement	06-03-2021 17:30	06-03-2021 17:51	21	All consumers under Srijan Cement Feeder	896	896	PLSRI202103060037			0.0003

Un-Planned OutageName of the Licensee: *INDIA POWER CORPORATION LIMITED*From Date : *01-03-2021*To Date : *07-03-2021*

Sl. No.	Feeder / Transformer Name & Number	Time of outage	Time of Restoration	Duration in minutes	Affected area connected to respective feeder /substation	Input load in kW at the time of outage	Input load in kW at the time of restoration	Interruption Reference Number	No. of Objection received from Consumers	Reply given to the objections	Estimated Energy loss in MU
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
1	Srijan Cement	01-03-2021 02:59	01-03-2021 05:25	146	All consumers under Srijan Cement Feeder	968	968	UPSRI202103010034			0.0024
2	Anjana Rice mill (11 KV)	01-03-2021 11:54	01-03-2021 14:55	181	All consumers under Anjana Rice mill (11 KV) Feeder	1027	280	UPANJ202103010038			0.0020
3	East Ring -1 (11 KV)	01-03-2021 14:42	01-03-2021 15:00	18	All consumers under East Ring -1 (11 KV) Feeder	187	93	UPEAS202103010005			0.0000
4	Raniganj Section 1	07-03-2021 09:20	07-03-2021 14:15	295	All consumers under Raniganj Section 1 Feeder	638	638	UPRAN202103070020			0.0031