

Planned Outage

Name of the Licensee: *INDIA POWER CORPORATION LIMITED*
 From Date : *22-02-2021*

To Date : *28-02-2021*

Sl. No.	Feeder / Transformer Name & Number	Time of outage	Time of Restoration	Duration in minutes	Affected area connected to respective feeder /substation	Input load in kW at the time of outage	Input load in kW at the time of restoration	Interruption Reference Number	No. of Objection received from Consumers	Reply given to the objections	Estimated Energy loss in MU
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
1	Srijan Cement	22-02-2021 09:05	22-02-2021 10:11	66	All consumers under Srijan Cement Feeder	968	968	PLSRI202102220026			0.0011
2	India Refractory (11 KV)	22-02-2021 10:00	22-02-2021 12:30	150	All consumers under India Refractory (11 KV) Feeder	187	93	PLIND202102220033			0.0004
3	Seebpore-Ikrah R/M	22-02-2021 10:03	22-02-2021 10:25	22	All consumers under Seebpore-Ikrah R/M Feeder	18967	18967	PLSEE202102220010			0.0070
4	Srijan Cement	22-02-2021 17:20	22-02-2021 17:47	27	All consumers under Srijan Cement Feeder	987	987	PLSRI202102220027			0.0004
5	Srijan Cement	24-02-2021 09:58	24-02-2021 12:53	175	All consumers under Srijan Cement Feeder	635	635	PLSRI202102240028			0.0019
6	Anjana Rice mill (11 KV)	24-02-2021 10:00	24-02-2021 12:30	150	All consumers under Anjana Rice mill (11 KV) Feeder	747	187	PLANJ202102240037			0.0012
7	JKNagar-Ikrah R/M	24-02-2021 10:45	24-02-2021 13:12	147	All consumers under JKNagar-Ikrah R/M Feeder	11356	11356	PLJKN202102240014			0.0278
8	Seebpore-Ikrah R/M	24-02-2021 10:48	24-02-2021 12:53	125	All consumers under Seebpore-Ikrah R/M Feeder	17589	17589	PLSEE202102240011			0.0366
9	Srijan Cement	24-02-2021 17:40	24-02-2021 18:04	24	All consumers under Srijan Cement Feeder	563	563	PLSRI202102240029			0.0002
10	Shyam Sel 33 KV Feeder	27-02-2021 18:55	27-02-2021 19:45	50	All consumers under Shyam Sel 33 KV Feeder Feeder	3772	1257	PLSHY202102270008			0.0021

Un-Planned Outage

Name of the Licensee: *INDIA POWER CORPORATION LIMITED*
 From Date : *22-02-2021*

To Date : *28-02-2021*

Sl. No.	Feeder / Transformer Name & Number	Time of outage	Time of Restoration	Duration in minutes	Affected area connected to respective feeder /substation	Input load in kW at the time of outage	Input load in kW at the time of restoration	Interruption Reference Number	No. of Objection received from Consumers	Reply given to the objections	Estimated Energy loss in MU
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
1	Tr. No. 1 at LRS	26-02-2021 11:07	26-02-2021 19:21	494	All consumers under Tr. No. 1 at LRS Feeder	1508	321	UPTRN202102260011			0.0075
2	East Ring 2 (11 KV)	28-02-2021 13:33	28-02-2021 15:15	102	All consumers under East Ring 2 (11 KV) Feeder	373	93	UPEAS202102280017			0.0004